

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. नि.अ./सामु.स्वा.के./अना./2025/666

Dated: 30/10/2025

It is certified that an inspection team headed by Dr. Ravindra Kumar M.A.C. CHC Badli GBN

(Name of Officers with designation) from Health Department U.P. PHED

inspected the ST. TERESA SCHOOL NH-91, SADOPUR GR Noida

(Name & Address of the school) on 30/10/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. UPTN/2025-26/B/079 dated 30/10/2025

of Water Testing Laboratory Ghaziabad (PHED Lab) certified that the

ST. TERESA SCHOOL NH-91, SADOPUR GR Noida GBN Nagar Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till One year

Signature with Seal: Dr. Ravindra Kumar

Name

Designation

Name & Address of the Office / Department

डा. रविन्द्र कुमार
विक्रित्ता अधीक्षक
सामुदायिक स्वास्थ्य केंद्र
बादली, गतिमंदिरा


Dr. Ravindra Kumar
M.A.C., CHC Badli GBN Nagar
CHC Badli
GB Nagar

To


ST. TERESA SCHOOL NH-91
SADOPUR GR Noida GBN Nagar
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

For St. Teresa School (Sadopur)


Principal

For St. Teresa School (Sadopur)


Manager


कार्यालय चिकित्सा अधीक्षक सामुदायिक स्वास्थ्य केन्द्र, दादरी गौतमबुद्धनगर।

पत्रांक:- वि०अ० / सामु०स्वा०के० / अना० / 2025 / 666


दिनांक:- 10.2025

अनापत्ति प्रमाण पत्र


प्रमाणित किया जाता है कि ST.Teresa School, NH-91, Sadopur, Greater Noida, G.B Nagar, का निरीक्षण करने पर उक्त स्कूल की पेयजल सफाई शौचालय एवं मूत्रालय लगभग सही पाये गए एवं जो कुछ कमिया थी, इस शर्त के साथ कि स्कूल प्रबन्धन उसे शीघ्र ही दुरुस्त करा लेगा यह अनापत्ति पत्र निर्गत किया जाता है।


Pharmacist
Community Health Center
Dadri (G.B. Nagar)

For St. Teresa School (Sadopur)


Principal

For St. Teresa School (Sadopur)


Manager


चिकित्सा अधीक्षक
सामुदायिक स्वास्थ्य केन्द्र, दादरी
गौतमबुद्धनगर।

डा. रविन्द्र कुमार
चिकित्सा अधीक्षक
सामुदायिक स्वास्थ्य केन्द्र
दादरी, गौतमबुद्धनगर

	WATER TESTING LABORATORY 120 MLD, WATER TREATMENT PLANT, GANGA JAL PROJECT, PRATAP VIHAR, GHAZIABAD- 201009	 TC-15179
	TEST REPORT	

Lab Address	120 MLD Water Treatment Plant, Ganga Jal Project, Pratap Vihar, Ghaziabad				
Customer Name and Address	Principal ST Teresa School NH- 91, Sadopur, Greater Noida. G. B. Nagar. (U. P.)	Lab Temperature During Testing	24.3°C		
Test Report No.	UPJN/2025-26/B/079	Test Start Date:	29.10.2025		
Sample Description	Drinking Water Sample from ST Teresa NH- 91, Sadopur, Greater Noida. G. B. Nagar. (U. P.)	Test Completion Date	30.10.2025		
Specification	IS 10500:2012 Amendment No. 2	Issued Date	30.10.2025		
Sample Packaging Details	Sample Sealed (02 Litres)				
Environment conditions at Lab During Testing	25°C± 3°C	Sample code	UPJN/2025-26/B/079		
Sr No	Test Parameters / Unit	Test Result	Requirement as Per IS 10500:2012		Test Method
			Acceptable Limit	Permissible Limit	
1	pH	7.08	6.50 - 8.50	No Relaxation	IS: 3025 Pt-11:2022
2	Turbidity (NTU)	0.31	1.0	5.0	IS: 3025 Pt-10:2024
3	Total Hardness (as CaCO3) mg/l	128.00	200	600	IS: 3025 Pt-21:2023
4	Calcium (as Ca) mg/l	24.04	75	200	IS: 3025 Pt-40:2024
5	Magnesium (as Mg) mg/l	11.49	30	100	IS: 3025 Pt-46:2023
6	Chloride (as Cl) mg/l	12.99	250	1000	IS: 3025 Pt-32:2019
7	Total Dissolved Solids, mg/l	194.00	500	2000	IS: 3025 Pt-16:2023
8	Total Solids, mg/l	214.00	--	--	IS: 3025 Pt-15:2009
9	Conductivity, µS/cm	318.00	--	--	IS:3025, Pt-14:2019

DECLARATION:

- This test report refers to items submitted for testing only.
- This test report shall not be re-produced except in full unless written permission for the publication of an approved abstract has been obtained from WTL.
- The test results reported in this report are valid at the time and under the stated conditions of testing
- Sampling is not done by WTL, Sample is provided by the customer.

--- End of Report---

Reviewed By:



Name: Hari Sharan

Designation: Chemist

Doc.. NO. WTL /F/TR/01, Rev-00

Authorized Signatory



Name: Kishan Singh Adhikari

Designation: Technical Head

Page-1 of 1

For St. Teresa School (Sadopur)


Principal

For St. Teresa School (Sadopur)


Manager



**OFFICE OF THE EXECUTIVE ENGINEER GANGA JAL PROJECT UNIT,
U.P. JAL NIGAM (URBAN) 120 MLD W.T.P. LABORATORY,
PRATAP VIHAR, GHAZIABAD-201009**

Letter No. 1773 /

4225

/ 167

Dated 30/10/2025

To

Principal
ST Teresa School
NH - 91, Sadopur, Greater Noida.
G. B. Nagar. (U. P.)

Sub :- Physical and Chemical analysis of water sample

Dear Sir

The water analysis report for the water sample (01 No.) sent along with your letter No. STS / 2025-26 / 01 Dated 29.10.2025 the physical and chemical analysis report is enclosed with this letter.

Drinking Water Sample From ST Teresa School
NH- 91, Sadopur, Greater Noida.
G. B. Nagar. (U. P.)

:- 1 No.

Total :- 1 No.


Enclosers : As Above.


Executive Engineer

For St. Teresa School (Sadopur)

For St. Teresa School (Sadopur)


Principal


Manager



120 MLD WATER TREATMENT PLANT LAB U.P. JAL NIGAM, GHAZIABAD

TRNo. 002218

Letter No.- 1773

Testing

167

Dated : 30/10/2025

DRINKING WATER ANALYSIS REPORT

Sample Sealed	:	Yes
Name of person Collected Sample	:	Sh. Yatish Kumar
Date & Time of Sample Collection	:	29.10.2025
Particulars/Source of Sample	:	Drinking Water Sample from ST Teresa School NH- 91, Sadopur, Greater Noida. G. B. Nagar. (U. P.)
Date of receipt of sample at Lab	:	29.10.2025
Sender Ref. No.	:	STS / 2025-26 / 01 Dated 29.10.2025
	By	Principal ST Teresa School NH- 91, Sadopur, Greater Noida. G. B. Nagar. (U. P.)
Laboratory analysis Ref. No.	:	PC-3960 Date: 30.10.2025

Test Results: Physico-Chemical Characteristics As per IS 10500 : 2012 as Amendment

No. 2

Sl.No.	Characteristic	Expressed as	Analysed result	Acceptable limit	Permissible limit
1	2	3	4	5	6
1	Sulphate (as SO ₄)	mg/l	14.00	200	400
2	Fluoride (as F)	mg/l	0.22	1.0	1.5
3	Nitrate (as NO ₃)	mg/l	2.80	45	No relaxation
4	Iron (as Fe)	mg/l	BDL	1.0	No relaxation
5	Residual Chlorine	mg/l	Nil	0.2	1.0

- Note :- (i) Figures in Col-5 are the limits up to which drinking water is acceptable to the consumers.
(ii) Figures in excess of Col-6 render the water not acceptable, but still may be tolerated (up to the limit indicated in the Col-6) in the absence of alternative and better source.
(iii) The water sample is not collected by us.
(iv) BDL- Below Detection Limit.

Test Conducted By

[Signature]

(For M/S Pooja Construction Co.)

COUNTER SIGNED BY

[Signature]
30/10/2025
J. E. A.E.

[Signature]
Executive Engineer

For St. Teresa School (Sadopur)

For St. Teresa School (Sadopur)

[Signature]
Principal

[Signature]
Manager